



Trow Associates Inc.

1595 Clark Boulevard
Brampton, Ontario
L6T 4V1

Telephone: (905) 793-9800
Facsimile: (905) 793-0641

Reference: LACA0056208W

February 25, 2010

Mr. Eric Hamdic
Newtonbrook Block
P.O. Box 69
2665 Aurora Side Road
Gormley, Ontario
L0H 1G0

Via Facsimile:
905-727-4910

Dear Mr. Hamdic:

**Precast Concrete Pavers
P.O. #781564**

Further to receipt of seven (7) Artisan precast concrete pavers in our laboratory on February 17, 2010 testing has been carried out as per your instructions.

Testing for compressive strength, durability and dimension check was conducted in accordance with the Canadian Standard Association CAN/CSA-A231.2-06, "Precast Concrete Pavers". Testing for density and absorption was conducted in accordance with ASTM Designation: C642-90, "Specific Gravity, Absorption and Voids in Hardened Concrete".

Yours truly,

Trow Associates Inc.


A handwritten signature in black ink, appearing to read 'Ammanuel Yousif', is written over a faint, larger version of the signature.

Ammanuel Yousif, C.E.T.
Senior Technician
Materials and Systems Testing

**Trow - Materials and Systems Testing
Laboratory Testing of Precast Concrete Pavers**

| Specimen No. | Product I.D. | Length (mm) | Width (mm) | Height (mm) | Cube Size (mm) | Strength (MPa) | 24 Hour | |
|----------------|----------------|-------------|------------|-------------|----------------|----------------|----------------|----------------------------------|
| | | | | | | | Absorption (%) | Wet Density (kg/m ³) |
| 1 | Artisan Pavers | 150 | 70 | 60 | 60 | 96.4 | | |
| 2 | Artisan Pavers | 150 | 70 | 60 | 60 | 94.3 | | |
| 3 | Artisan Pavers | 150 | 70 | 60 | 60 | 92.6 | | |
| 4 | Artisan Pavers | 150 | 70 | 60 | 60 | 93.7 | | |
| 5 | Artisan Pavers | 150 | 70 | 60 | 60 | 88.9 | | |
| 6 | Artisan Pavers | 150 | 70 | 60 | 60 | | 0.78 | 2383 |
| 7 | Artisan Pavers | 150 | 70 | 60 | 60 | | 0.90 | 2317 |
| Average | | | | | | | 0.84 | 2319 |

Manufacturer: Newtonbrook Block
Date Tested: February 23, 2010
Date of Manufacturer: November 5, 2009
Project Number: LACA0056208W

Testing Laboratory Representative Signature


February 25, 2010
 Date